



Energy Savings with Pump Systems

- How important are pump systems?
- Some pump system theory
- Prescreen pump systems: the VITAL FEW and the trivial many
- Identifying energy savings opportunities

1

University City Science Center
ITEM Division



Big Picture Perspectives: Industrial Motor Systems

➤ Industrial motor systems:


- Are the *single largest electrical end use* category in the American economy
- Account for 25% of U.S. electrical sales



2

University City Science Center
ITEM Division

Industrial motor energy use by application



Source: United States Industrial Electric Motor Systems Market Opportunities Assessment, Office of Industrial Technologies, Office of Energy Efficiency and Renewable energy, US DOE, December 1998, Table 1-16, page 43

University City Science Center
ITEM Division

Important fundamental relationship




$$\text{Fluid power} = \frac{\text{Flow rate (gpm)} \times \text{Head (ft)} \times \text{specific gravity}}{3960} \text{ (hp)}$$

AND

$$\text{Fluid energy} = \text{Fluid power} \times \text{operating time}$$

<p>Reduce the run time</p> <p>Reduce the flow rate</p> <p>Reduce the head</p>	}	Reduce energy use, cost
---	---	-------------------------

Ideally, fluid movement energy requirements are proportional to mass and head




Energy required = 10000 ft-lb, or
3.24 kcalories
(less than one M&M)

5

University City Science Center
ITEM Division

Ideal power depends
on how fast it is moved




Power required = 0.1 horsepower, or
65 kcalories per hour

6

University City Science Center
ITEM Division

The Bernoulli equation is slightly modified to account for friction:

$$\left(\frac{V_1^2}{2g} + \frac{P_1}{\gamma} + Z_1 \right) = \left(\frac{V_2^2}{2g} + \frac{P_2}{\gamma} + Z_2 \right) + H_f$$


Hydraulic energy at point 2 is lower than at point 1 because of the friction loss, so we balance the equation by adding it here

7

University City Science Center
ITEM Division

Pipe friction loss estimates are usually based on an equation referred to as Darcy-Weisbach

This equation is very useful to understand what parameters influence *frictional* losses in piping:

$$H_f = f \cdot \frac{L}{d} \cdot \frac{V^2}{2g}$$

- H_f = pressure drop due to friction (ft)
- f = Darcy friction factor
- L = pipe length (ft)
- d = pipe diameter (ft)
- $\frac{V^2}{2g}$ = velocity head (ft)

8

University City Science Center
ITEM Division

Component friction losses are primarily dependent on experimental data



For pipe components, frictional losses have generally been estimated based on the velocity head.

$$H_f = K \cdot \frac{V^2}{2g}$$


K = Loss coefficient
 $\frac{V^2}{2g}$ = velocity head

K is a function of size, and for valves, the valve type, and valve % open.

9

University City Science Center
ITEM Division


System head curves for all frictional, all static, and combined static and frictional systems



10

University City Science Center
ITEM Division

The system operating point is at the intersection of the pump and system head-capacity curves



11

University City Science Center
ITEM Division

Pump affinity laws can be used to predict pump curves for different speeds and impeller diameters



Speed

$$\left(\frac{Q_1}{Q_2}\right) = \left(\frac{N_1}{N_2}\right)^1$$

$$\left(\frac{H_1}{H_2}\right) = \left(\frac{N_1}{N_2}\right)^2$$

$$\left(\frac{P_1}{P_2}\right) = \left(\frac{N_1}{N_2}\right)^3$$

Diameter

$$\left(\frac{Q_1}{Q_2}\right) = \left(\frac{D_1}{D_2}\right)^1$$

$$\left(\frac{H_1}{H_2}\right) = \left(\frac{D_1}{D_2}\right)^2$$


$$\left(\frac{P_1}{P_2}\right) = \left(\frac{D_1}{D_2}\right)^3$$

Q = flow rate H = head P = power N = speed D = diameter

12

University City Science Center
ITEM Division


Isoefficiency lines are frequently overlaid onto head-capacity curves for multiple impeller diameters



13

University City Science Center
ITEM Division


Isoefficiency lines for different shaft speeds



14

University City Science Center
ITEM Division


Identical pumps in series; add head at a given flow rate to estimate overall performance



15


University City Science Center
ITEM Division

Parallel pumps can help adapt to changing system requirements and provide redundancy



16

University City Science Center
ITEM Division




Symptoms that indicate potential opportunity

<u>Symptom</u>	<u>Likely Reason</u>	<u>Best Solutions</u>
Throttle valve-controlled systems	Oversized pump	Trim Impeller, Smaller Impeller, ASD
Bypass line (partially or completely) open	Oversized pump	Trim Impeller, Smaller Impeller, ASD
Multiple parallel pump system with the same number of pumps always operating	Pump use not monitored or controlled	Install controls
Constant pump operation in a batch environment	Wrong system design	On-off controls
Frequent batch operation in a continuous process	Wrong system design	Match pump capacity with system requirement
Presence of cavitation noise (at pump or elsewhere in the process)	Various	Depends on cause
High maintenance cost (seals, bearings). Talk to operations personnel	Pump operated far away from B.E.P.	Match pump capacity with system requirement

18

University City Science Center
ITEM Division




-
- Corrections for oversized pumps include:
- Replace the impeller of the existing pump with a smaller impeller
 - Trim the outside diameter of the existing impeller
 - Use an adjustable speed drive (ASD) to drive the pump
- 20
- University City Science Center
ITEM Division

Bypass (recirculation) line partially or completely open



Bypass valve (completely or partially open)




21

University City Science Center
ITEM Division

Multiple parallel pump system with same number of pumps always operating




Pumps always on



22

University City Science Center
ITEM Division

Three pumps in parallel




Take a good look at the diagram and you will see that the third pump (C) is intersecting the system curve at just about the same point as the second pump (B).

All of this means that the capacity of three pumps running will not be much greater than that of two pumps running.

23

University City Science Center
ITEM Division


Constant pump operation in a batch environment



24

University City Science Center
ITEM Division

Frequent cycle batch operation in a continuous process



25

University City Science Center
ITEM Division